


Lead in Water Testing

New in 2023-24, Minnesota State Statute 121A.335 requires public and charter schools to have a plan for efficiently and accurately testing for lead in drinking water using the model plan developed by MDE and MDH or by adopting an alternative plan. The law applies in addition to any other current testing requirements. The full Statute can be found on the MN Department of Health website at: health.state.mn.us.

The Nevis School District worked with Elite Environmental Services, LLC in November and December 2023 to test the district's potable water for lead. The following documents contain specific test results.

A summary of the results was provided by EES, LLC and is as follows:

The Nevis School District collected fifty-seven (57) total lead in water samples, from every potable source of drinking water in the building and the samples were received in good condition at the Minnesota Department of Health (MDH). None of the fifty-seven (57) lead in water samples exceeded the hazardous/action level of 5.0 ppb. No further action is necessary. EES recommends that the district retest the potable water sources five years from the date 12/20/2023.



Final Report

Minnesota Department of Health
Public Health Laboratory
Environmental Laboratory Section
601 Robert St. N., P.O. Box 64899
St. Paul, MN 55164-0899
651-201-5300

PWSID: Nevis School
System Name: 0308-01
City: None

Program Code: HK

Type:

Date Received: 11/27/23 07:26
Rep. Temp. (°C): 4.1

Collector Name: Facility Staff
Collector ID: None

MDH Sample Number: 23K1136-01

Location ID: 406468
Sampling Point: Rm 132

Collect Date: 11/20/23
Collect Time: 11:25
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 21:56	RCC	EPA 200.8	

MDH Sample Number: 23K1136-02

Location ID: 406467
Sampling Point: Rm 131

Collect Date: 11/20/23
Collect Time: 11:12
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.59	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 21:59	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-03

Location ID: 406466
Sampling Point: Rm 130

Collect Date: 11/20/23
Collect Time: 11:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:01	RCC	EPA 200.8	

MDH Sample Number: 23K1136-04

Location ID: 406465
Sampling Point: Rm 129

Collect Date: 11/20/23
Collect Time: 11:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.15	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:04	RCC	EPA 200.8	

MDH Sample Number: 23K1136-05

Location ID: 406464
Sampling Point: Rm 128

Collect Date: 11/20/23
Collect Time: 11:36
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:07	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-06

Location ID: 406463
Sampling Point: Rm 127

Collect Date: 11/20/23
Collect Time: 11:41
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.03	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:09	RCC	EPA 200.8	

MDH Sample Number: 23K1136-07

Location ID: 406462
Sampling Point: In hall outside of 303

Collect Date: 11/20/23
Collect Time: 11:43
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:17	RCC	EPA 200.8	

MDH Sample Number: 23K1136-08

Location ID: 406461
Sampling Point: Outside room 303 west fixture

Collect Date: 11/20/23
Collect Time: 11:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0601	12/11/23 16:50	12/11/23 22:20	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-09

Location ID: 406460

Sampling Point: Outside room 303 East fixture

Collect Date: 11/20/23

Collect Time: 11:43

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:39	RCC	EPA 200.8	

MDH Sample Number: 23K1136-10

Location ID: 406459

Sampling Point: Sink in rm N ECFE room

Collect Date: 11/20/23

Collect Time: 11:49

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:42	RCC	EPA 200.8	

MDH Sample Number: 23K1136-11

Location ID: 406458

Sampling Point: Sink in ECFE kitchenette

Collect Date: 11/20/23

Collect Time: 11:47

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:45	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-12

Location ID: 406457
Sampling Point: Sink in S ECFE room

Collect Date: 11/20/23
Collect Time: 11:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:47	RCC	EPA 200.8	

MDH Sample Number: 23K1136-13

Location ID: 406456
Sampling Point: Rm 126

Collect Date: 11/20/23
Collect Time: 11:38
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:50	RCC	EPA 200.8	

MDH Sample Number: 23K1136-14

Location ID: 406455
Sampling Point: Rm 124

Collect Date: 11/20/23
Collect Time: 11:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.00	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:53	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-15

Location ID: 406454
Sampling Point: Rm 123

Collect Date: 11/20/23
Collect Time: 11:13
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:55	RCC	EPA 200.8	

MDH Sample Number: 23K1136-16

Location ID: 406453
Sampling Point: Rm 122

Collect Date: 11/20/23
Collect Time: 11:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.75	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 12:58	RCC	EPA 200.8	

MDH Sample Number: 23K1136-17

Location ID: 406452
Sampling Point: Rm 121

Collect Date: 11/20/23
Collect Time: 11:06
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.20	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:06	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-18

Location ID: 406450	Collect Date: 11/20/23	Field Residual Chlorine Result: None
Sampling Point: Outside of elementary boys bathroom	Collect Time: 11:55	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:08	RCC	EPA 200.8	

MDH Sample Number: 23K1136-19

Location ID: 406449	Collect Date: 11/20/23	Field Residual Chlorine Result: None
Sampling Point: Outside of elementary girls bathroom	Collect Time: 11:56	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:11	RCC	EPA 200.8	

MDH Sample Number: 23K1136-20

Location ID: 406448	Collect Date: 11/20/23	Field Residual Chlorine Result: None
Sampling Point: Kitchen	Collect Time: 13:48	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.00	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:14	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-21

Location ID: 406451
Sampling Point: Kitchen

Collect Date: 11/20/23
Collect Time: 13:45
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:16	RCC	EPA 200.8	

MDH Sample Number: 23K1136-22

Location ID: 406447
Sampling Point: Kitchen

Collect Date: 11/20/23
Collect Time: 13:46
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	3.00	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:19	RCC	EPA 200.8	

MDH Sample Number: 23K1136-23

Location ID: 406446
Sampling Point: Kitchen

Collect Date: 11/20/23
Collect Time: 13:42
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.76	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:21	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-24

Location ID: 406445
Sampling Point: In cafeteria

Collect Date: 11/20/23
Collect Time: 12:49
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:24	RCC	EPA 200.8	

MDH Sample Number: 23K1136-25

Location ID: 406444
Sampling Point: Cafeteria

Collect Date: 11/20/23
Collect Time: 12:48
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:27	RCC	EPA 200.8	

MDH Sample Number: 23K1136-26

Location ID: 406443
Sampling Point: Hallway by 6th grade room

Collect Date: 11/20/23
Collect Time: 12:53
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0613	12/12/23 10:13	12/12/23 13:35	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-27

Location ID: 406442
Sampling Point: Hallway by 6th grade room

Collect Date: 11/20/23
Collect Time: 12:54
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 13:48	RCC	EPA 200.8	

MDH Sample Number: 23K1136-28

Location ID: 406439
Sampling Point: Teacher lounge

Collect Date: 11/20/23
Collect Time: 12:57
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 13:50	RCC	EPA 200.8	

MDH Sample Number: 23K1136-29

Location ID: 406438
Sampling Point: Room 119

Collect Date: 11/20/23
Collect Time: 13:00
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.32	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 13:53	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-30

Location ID: 406437

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:50

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.55	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:01	RCC	EPA 200.8	

MDH Sample Number: 23K1136-31

Location ID: 406441

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:51

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:03	RCC	EPA 200.8	

MDH Sample Number: 23K1136-32

Location ID: 406440

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:52

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.08	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:06	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-33

Location ID: 406436

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:53

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.32	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:09	RCC	EPA 200.8	

MDH Sample Number: 23K1136-34

Location ID: 406435

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:54

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	2.00	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:11	RCC	EPA 200.8	

MDH Sample Number: 23K1136-35

Location ID: 406434

Sampling Point: Science Room 168

Collect Date: 11/21/23

Collect Time: 06:55

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	4.28	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:14	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-36

Location ID: 406433

Sampling Point: Room 171

Collect Date: 11/21/23

Collect Time: 06:59

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:17	RCC	EPA 200.8	

MDH Sample Number: 23K1136-37

Location ID: 406432

Sampling Point: Wood shop room 175

Collect Date: 11/21/23

Collect Time: 07:05

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	1.10	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:24	RCC	EPA 200.8	

MDH Sample Number: 23K1136-38

Location ID: 406431

Sampling Point: High school hall

Collect Date: 11/21/23

Collect Time: 07:08

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:27	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*

PWSID: Nevis School

MDH Sample Number: 23K1136-39

Location ID: 406430
Sampling Point: High school hall

Collect Date: 11/21/23
Collect Time: 07:09
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:30	RCC	EPA 200.8	

MDH Sample Number: 23K1136-40

Location ID: 406429
Sampling Point: High school hall

Collect Date: 11/21/23
Collect Time: 07:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:32	RCC	EPA 200.8	

MDH Sample Number: 23K1136-41

Location ID: 406428
Sampling Point: Art room 184

Collect Date: 11/21/23
Collect Time: 07:10
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:35	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-42

Location ID: 406427
Sampling Point: Art room 184

Collect Date: 11/21/23
Collect Time: 07:11
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:38	RCC	EPA 200.8	

MDH Sample Number: 23K1136-43

Location ID: 406426
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:40	RCC	EPA 200.8	

MDH Sample Number: 23K1136-44

Location ID: 406425
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:31
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:43	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-45

Location ID: 406424
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:32
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:51	RCC	EPA 200.8	

MDH Sample Number: 23K1136-46

Location ID: 406423
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:33
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0614	12/12/23 10:18	12/12/23 14:53	RCC	EPA 200.8	

MDH Sample Number: 23K1136-47

Location ID: 406422
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:34
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:06	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-48

Location ID: 406421
Sampling Point: Rm 154

Collect Date: 11/21/23
Collect Time: 07:35
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:09	RCC	EPA 200.8	

MDH Sample Number: 23K1136-49

Location ID: 406420
Sampling Point: Rm 153

Collect Date: 11/22/23
Collect Time: 07:09
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:12	RCC	EPA 200.8	

MDH Sample Number: 23K1136-50

Location ID: 406419
Sampling Point: Concession stand

Collect Date: 11/22/23
Collect Time: 06:55
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:20	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-51

Location ID: 406418
Sampling Point: Tiger Arena

Collect Date: 11/22/23
Collect Time: 06:59
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:22	RCC	EPA 200.8	

MDH Sample Number: 23K1136-52

Location ID: 406417
Sampling Point: Tiger Arena

Collect Date: 11/22/23
Collect Time: 06:58
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:25	RCC	EPA 200.8	

MDH Sample Number: 23K1136-53

Location ID: 406416
Sampling Point: Outside rm 156

Collect Date: 11/22/23
Collect Time: 07:01
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:28	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-54

Location ID: 406415
Sampling Point: Outside room 156

Collect Date: 11/22/23
Collect Time: 07:02
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:30	RCC	EPA 200.8	

MDH Sample Number: 23K1136-55

Location ID: 406414
Sampling Point: Outside rm 156

Collect Date: 11/22/23
Collect Time: 07:03
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:33	RCC	EPA 200.8	

MDH Sample Number: 23K1136-56

Location ID: 406413
Sampling Point: Outside Tiger Arena bathrooms

Collect Date: 11/22/23
Collect Time: 07:06
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:35	RCC	EPA 200.8	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

MDH Sample Number: 23K1136-57

Location ID: 406408

Sampling Point: Outside Tiger Arena bathrooms

Collect Date: 11/22/23

Collect Time: 07:05

Matrix: Drinking Water

Field Residual Chlorine Result: None

Field Fluoride Result: None

Field pH Result: None

Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3L0615	12/12/23 10:21	12/12/23 15:43	RCC	EPA 200.8	

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*

PWSID: Nevis School

Results were produced by Minnesota Department of Health, except where noted.

Batch B3L0601 - EPA 200 Series Prep

Blank (B3L0601-BLK1)

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 21:09

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3L0601-BS1)

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 21:11

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.1		ug/L	50		98	85-115			RCC	

Duplicate (B3L0601-DUP1)

Source: 23K0845-12

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 21:22

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	1.43	1.00	ug/L		1.44			0.6	20	RCC	

Duplicate (B3L0601-DUP2)

Source: 23K1136-06

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 22:12

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	1.92	1.00	ug/L		2.03			6	20	RCC	

Matrix Spike (B3L0601-MS1)

Source: 23K0845-12

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 21:24

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.8		ug/L	50		97	70-130			RCC	

Matrix Spike (B3L0601-MS2)

Source: 23K1136-06

Prepared: 12/11/23 16:50 Analyzed: 12/11/23 22:15

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.1		ug/L	50		92	70-130			RCC	

Batch B3L0613 - EPA 200 Series Prep

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

Results were produced by Minnesota Department of Health, except where noted.

Batch B3L0613 - EPA 200 Series Prep

Blank (B3L0613-BLK1)

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 12:24

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3L0613-BS1)

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 12:26

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.8		ug/L	50		100	85-115			RCC	

Duplicate (B3L0613-DUP1)

Source: 23K0505-01

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 12:34

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.12	1.00	ug/L		<			2	20	RCC	

Duplicate (B3L0613-DUP2)

Source: 23K1136-25

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 13:29

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.12	1.00	ug/L		<			1	20	RCC	

Matrix Spike (B3L0613-MS1)

Source: 23K0505-01

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 12:37

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	44.0		ug/L	50		88	70-130			RCC	

Matrix Spike (B3L0613-MS2)

Source: 23K1136-25

Prepared: 12/12/23 10:13 Analyzed: 12/12/23 13:32

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	46.6		ug/L	50		93	70-130			RCC	

Batch B3L0614 - EPA 200 Series Prep

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

Results were produced by Minnesota Department of Health, except where noted.

Batch B3L0614 - EPA 200 Series Prep

Blank (B3L0614-BLK1)

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 13:42

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3L0614-BS1)

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 13:45

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	49.5		ug/L	50		99	85-115			RCC	

Duplicate (B3L0614-DUP1)

Source: 23K1136-29

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 13:56

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	1.27	1.00	ug/L		1.32			4	20	RCC	

Duplicate (B3L0614-DUP2)

Source: 23K1136-44

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 14:45

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.32	1.00	ug/L		<			0.5	20	RCC	

Matrix Spike (B3L0614-MS1)

Source: 23K1136-29

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 13:58

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	50.4		ug/L	50		98	70-130			RCC	

Matrix Spike (B3L0614-MS2)

Source: 23K1136-44

Prepared: 12/12/23 10:18 Analyzed: 12/12/23 14:48

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	47.1		ug/L	50		94	70-130			RCC	

Batch B3L0615 - EPA 200 Series Prep

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

Results were produced by Minnesota Department of Health, except where noted.

Batch B3L0615 - EPA 200 Series Prep

Blank (B3L0615-BLK1)

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 15:01

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3L0615-BS1)

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 15:04

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	51.9		ug/L	50		104	85-115			RCC	

Duplicate (B3L0615-DUP1)

Source: 23K1136-49

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 15:14

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	0.93	1.00	ug/L		<			0.1	20	RCC	

Duplicate (B3L0615-DUP2)

Source: 23K1337-01

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 16:04

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	2.08	1.00	ug/L		2.11			1	20	RCC	

Matrix Spike (B3L0615-MS1)

Source: 23K1136-49

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 15:17

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	50.1		ug/L	50		98	70-130			RCC	

Matrix Spike (B3L0615-MS2)

Source: 23K1337-01

Prepared: 12/12/23 10:21 Analyzed: 12/12/23 16:07

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.1		ug/L	50		92	70-130			RCC	

FINAL REPORT

Report ID: 12132023160436

Generated: 12/13/2023 4:04:33PM

Authorized by:

The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Nevis School

Work Order Comments

Samples were received in proper condition.

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health